

Annual Drinking Water Quality Report for 2023
Bright Acres Water District
1 Town Hall Drive – Lake Katrine, New York 12449
Public Water Supply ID# 5503408

Introduction:

To comply with State and Federal Regulations, the Bright Acres Water District will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and your awareness of the need to protect our drinking water supply. Last year, your tap water met all State drinking water standards. This report provides an overview of last years' water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **John Rose, Water Superintendent**, at **845-382-1833** or the **Ulster County Health Department at 845-340-3010**. If you would prefer contacting us via e-mail, our address is **watersewer@townofulster.ny.gov**. We want you to be informed about your drinking water. If you want to learn more, please attend any of the regularly scheduled town board meetings. The meetings are held at 7:00 p.m. on the third Thursday of each month at the Town Hall in Lake Katrine.

Where Does Our Water Come From?

In general, the sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contamination; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department and the FDA's regulations also establish limits for contaminants in bottled water which must provide the same protection for public health.

In 2023 The Bright Acres Water District was supplied with water from the Town of Ulster Water District thru a connection at the Cherry Hill/Sawkill Road Water District. This water is a blend of water from the Town of Ulster and Kingston Water Departments. A copy of the Town of Ulster's and/or City of Kingston's Annual Drinking Water Quality Report is available by contacting the Ulster Water Department at 845-382-1833.

Facts and Figures:

Our water system serves 105 customers through 40 service connections. The total water produced for the calendar year 2023 was 3,655,864 gallons. Daily average pumped to the system was 10,016 gallons. The highest single day total was 20,776 gallons on April 21st. The amount of water delivered to customers was 2,065,610 gallons. In 2023 there was an unaccounted for water loss of approximately 43%.

In 2023 water rates were as follows: 1st 9000 gallons or any portion thereof \$80.75; 9001-20,000 gallons \$7.79 per thousand or portion thereof; 20,001-50,000 gallons \$8.34 per thousand or portion thereof; 50,001gallons and above cost \$10.48 per thousand or portion thereof.

Are There Contaminants In Our Drinking Water?

As the State regulations require, we routinely test your drinking water for numerous contaminants. The contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, radiological and synthetic organic compounds. The table below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than a year old.

Table of Detected Contaminants							
Contaminant	Violation Yes / No	Date of Sample	Level Detected/ Average (Range)	Unit of Measurement	MCLG	Regulatory Limit MCL,TT or AL	Likely Source of Contaminant
Lead (1)	No	6/28/22	3.9 (<1.0-6.5)	ug/L	0	AL=15	Corrosion of household plumbing; Erosion of natural deposits.
Copper (2)	No	6/28/22	18 (<10-20)	ug/L	1300	AL=1300	Corrosion of household plumbing systems; Erosion of natural deposits.
TTHM's Trihalomethanes stage 2	No	2023	70.75 (47-99)	ug/L	N/A	MCL=80	By product of drinking water chlorination
HAA5's Haloacetic Acids stage 2	No	2023	22.9 (15-25)	ug/L	N/A	MCL=60	By product of drinking water chlorination
Barium	No	10/21/2021	0.083	mg/L	2	MCL=2	Runoff from fertilizer use; Discharge of drilling wastes; Discharge from metal refineries.
Nitrate	No	11/01/2023	0.17	mg/L	10	MCL=10	Erosion of natural deposits; Leaching from septic tanks, sewage; Erosion of natural deposits
Turbidity (3)	No	2023	.26	NTU	N/A	TT=<1NTU	Soil Runoff
Sodium (4)	No	09/09/2013	6.5	mg/L	N/A	See footnote #5	Naturally occurring; Water Softeners; Road Salt; Animal Waste
Nickel	No	10/21/2021	0.00081	Mg/L	N/A	N/A	

Notes:

- 1) The level presented represents the 90th percentile of the 4th and 5th ranked samples sites tested. The action level for lead was not exceeded at any of the five test sites.
- 2) The level presented represents the 90th percentile of the 4th and 5th ranked sample sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at our water system. Out of the 5 samples that were collected the average of the 4th and 5th highest samples taken was 21.5 ug/l. The action level for copper was not exceeded at any of the sites tested.
- 3) Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of water quality. High turbidity can hinder the effectiveness of disinfectants. Out of the 52 turbidity samples taken in Bright Acres in 2023, the highest measurement was .46 NTU. State regulations require that 95% of turbidity samples collected have measurements below 0.3 NTU and that all turbidity results are less than 1 NTU.
- 4) Water containing more than 20mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Definitions:

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as possible.

Maximum Contaminant Level Goal (MCLG): The level of contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Milligrams Per Liter(mg/l): Corresponds to one part of liquid to one million parts of liquid (parts per million = ppm)

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a drinking water disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

It should be noted that all drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Ulster County Health Department at 340-3010.

What Does This Information Mean?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Ulster Water District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Town of Ulster Water Department (845) 382-2434. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Do I Need To Take Special Precautions?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population.

Is Our Water System Meeting Other Rules That Govern Operations?

During 2023 our system was in compliance with all applicable State drinking water operating, monitoring and reporting requirements.

Why Save Water and How Do We Avoid Wasting It?

Although our area is very fortunate to have access to a water supply which currently more than meets our demands, conservation efforts by both the town and the consumer are prudent in deterring increasing costs. As a consumer you can participate in this water conservation effort. The following are some ideas that can be directly applied to your individual homes: 1) Use water-saving, flow-restricting shower heads and low flow faucets (aerators); 2) Repair dripping faucets and toilets that seem to flush by themselves; 3) Replace your toilet with a low flush model or place a brick in your tank to reduce the volume used on each flush; 4) Water your garden and lawn only when necessary. Remember that a layer of mulch in the flower beds and garden is not only aesthetically pleasing but will help retain moisture; 5) Water your lawn after 6:00pm, as this prevents water loss due to evaporation; 6) When washing your car don't let the hose run continuously; 7) When brushing your teeth, or when shaving or shampooing your hair try to avoid running the water unnecessarily; and lastly try whenever possible to wash clothes and run the dishwasher only when you have a full load.

Source Water Assessment:

The New York State Department of Health has completed a source water assessment for Well #1 and Well #2 of this system, based on available information. Possible and actual threats to these drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of source water, it does not mean the water delivered to consumers is, or will be contaminated. The source water assessments provide resource managers with additional information for protecting source waters in the future.

The source water assessment has rated these wells as having a high susceptibility to microbials, nitrates, industrial solvents and other industrial contaminants. These ratings are due primarily to the close proximity of permitted discharge facility (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government); a hazardous waste facility; a toxic chemical release facility; and low intensity residential activities in the assessment area. In addition, the wells draw from an unconfined aquifer and the overlying soils do not provide adequate protection from potential contamination. Please note that, while the source water assessment rates our wells as being susceptible to microbials, our water is disinfected to ensure that the finished water delivered to your home meets the New York State drinking water standards for microbial contamination.

A copy of this assessment, including a map of the assessment area, can be obtained by contacting us at the number listed above.

Security

This water system has increased preventive security measures to protect the water supply from vandalism. The public can also assist us by reporting any suspicious activities around water department facilities or properties.

Closing:

Thank you for allowing us to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call our office if you have questions.